

**SUPPLEMENTAL/BID BULLETIN NO. 1**

August 16, 2021

**CLARIFICATIONS/AMENDMENTS ON THE BIDDING DOCUMENTS FOR THE REPAIR
OF FASPO ANNEX BUILDING (PBD-21-08)**


This Supplemental/Bid Bulletin No.1 is issued to amend the information issued earlier relative to the abovementioned subject and provide clarifications on matters raised by interested bidders.

SECTIONS/ CLAUSES AFFECTED	AS STATED IN THE ORIGINAL BIDDING DOCUMENTS/QUERIES RAISED BY PROSPECTIVE BIDDERS	AMENDMENTS/CLARIFICATIONS
Section I: Invitation to Bid, Par. 8 Par. 10	<p>Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before August 20, 2021 at 9:00 a.m.</p> <p>Bid opening shall be conducted face to face on August 20, 2021 at 10:00 a.m.</p> <p>ASERON BUILDERS</p> <p>How many copies of the bid proposals shall be submitted?</p> <p>NOE's BUILDERS</p> <ol style="list-style-type: none">1. Are we required to submit all the other Sections of the PBD, such as the ITB, BDS, GCC and SCC?2. On Technical Specifications and BOQ<ul style="list-style-type: none">• Internal Walls under Concreting	<p>Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before August 23, 2021 at 9:00 a.m.</p> <p>Bid opening shall be conducted face to face on August 23, 2021 at 10:00 a.m. Bidders have the option to attend the bid opening using the online platform thru MS Teams apps.</p> <p>The simplified Philippine Bidding Documents 6th edition requires submission of only one copy of the bid proposals.</p> <p>Bidders are advised to carefully check and comply with the documents to be submitted during bid opening as provided for under Section IX Checklist of Technical and Financial Documents of the PBD.</p> <p>Internal walls under concreting and masonry works include repair of all</p>

	<p>and Masonry</p> <ul style="list-style-type: none"> • On tile works 	<p>existing drywall, CHB and all other wall finishes.</p> <p>Drywall, CHB and all other wall partitions will be based on the existing finishes. For all new additional drywall partitions, fiber cement board with metal studs and metal tracks will be used. Also, ceiling materials to be used will be based on existing finishes.</p> <p>Ceramic tiles (0.60m x 0.60m, 275 sqm.) will be used for all the floors. On the other hand, ceramic tiles (0.40m x 0.40m, 100 sqm.) will be used for toilet walls.</p> <p>Bidders are advised to conduct an ocular inspection of the proposed project in coordination with the Project Engineer for a better appreciation of the project's requirements.</p>
--	--	--

The foregoing shall form an integral part of the Bid Documents and supersede previous issuances relative to the subject procurement.

Approved by:
(For the BAC-Primary)


ATTY. JIM G. COLETO
 Board Member III, DAR Adjudication Board
 Chairperson, Bids & Awards Committee - Primary

